



Maharashtra Government
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK

Office Phone No.:- 0253 – 2570613

Email Id:- dphlnasik@gmail.com

Office: - Junior Scientific Officer District Public Health, Laboratory,
Civil Hospital Campus, Trimbak Road, Nashik - 422 001.

NO. DPHL/NSK/WC/ W-168/ 2206 /2025

Date:- 23 / 5 /2025

Health Services

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection- -----	Date of receipt- 25/04/2025	Date of Examination- 25/04/2025 & onwards
Letter No:--JIG/195/2024-2025		Dated: 25/04/2025

Analytical results in mg/litre (except pH & turbidity)

Sr. No.	Name of Test	Results	BIS Specification 10500:2012 Normal values	
			Acceptable limits	Permissible limits
	Source	RO filtered borewell water	-----	-----
01	Physical appearance	Clear, Colorless	-----	-----
02	Odor	Agreeable	Agreeable	Agreeable
03	pH	7.5	6.5 to 8.5	No relaxation
04	Turbidity (NTU)	0.10	1.0	5.0
05	Chlorides	14	250	1000
06	Total Hardness	136	200	600
07	Total alkalinity	235	200	600
08	Total dissolved solids	350	500	2000
09	Fluoride	0.04	1.0	1.5
10	Iron	0.125	1.0	No relaxation
11	Nitrates	1.13	45	No relaxation
12	Permanent hardness	NIL	-----	-----


Note: (A) It is presumed that the representative sample/s from the stock is/are sent for analysis.
(B) This report is restricted to the sample/s submitted in the laboratory. (C) This sample/s is/are not collected by this laboratory.

Remarks: Sample no. 01 contains Total alkalinity more than the prescribed limit. However, if there is no other alternative source available nearby then this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

Forwarded with compliments to:

Principal,
Jain International Gurukul,
Behind MUHS, Next to Sanap Nursery,
Manori Shivar, Dindori Road,
Tal. Dindori
Dist. Nashik

R.No: 5147013; Rs. 600; Dt: 25/04/2025


Junior Scientific Officer
District Public Health Laboratory,
Nashik.



JUNIOR SCIENTIFIC OFFICER,

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak Road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name:- ☒ Jain International Gurukul

Address :- Behind MUHS, 164, Manori shivar, Dindori Road, Tal. Dindori, Dist. Nashik.

Senders Letter No. & Date :- 14-05-2025

Date of Sample Collection :- 14-05-2025 Laboratory Reference No. :- 05/630/26

Date of Arrival at Laboratory :- 14-05-2025


Date of Commencing Examination:- 14-05-2025

Sr. No.	Particulars of Water Samples	Results of Analysis (As per IS 10500:2012)			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<i>E.coli</i>	
1	Filtered Water Sample	0	0	0	<u>Potable</u>
Receipt No :- 5147055		Fee Rs. :- 340/-			Date:- 14-05-2025
Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.					

Outward No:-

Date:-

1

2151/25
23.5.25

Junior Scientific Officer
District Public Health Laboratory,
Nashik.